Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

	RTY LOCATION: 275 Senter Ln, Bunnlevel
ISSUED TO: Kelly Fields SUBDI	VISION Senter Hills LOT # 25
Type of Structure: Existing SFD	Site Improvements required prior to Construction Authorization Issuance:
Proposed Wastewater System Type: 25% Reduction	
Projected Daily Flow: 360 GPD	
Number of bedrooms: 3 Number of Occupants: 6 max	
Basement Yes X No	
Pump Required: ☑Yes ☐ No ☐ May be required based on final location	
	well feet Permit valid for: Five years
Permit conditions:	No expiration
- 11 P.	
Authorized State Agent:	Date: 1/7/2020 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits.	The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This
site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit sh	all not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit	
	A 31 2 2
<u>Constructio</u>	n Authorization
	or Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. an with the attached system layout.	d .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.	
ISSUED TO: Kelly Fields	OPERTY LOCATION: 275 Senter Ln, Bunnlevel
	BDIVISION Senter hills LOT # 25
Facility Type: Existing SFD New	Expansion 🗵 Repair
Basement? Yes No Basement Fixtures? Yes No	1 5 5 6
Type of Wastewater System** Pump to 25%Reduction	(Initial) Wastewater Flow: 360 GPD
(See note below, if applicable)	
Pump to 25% Reduction	(Repair)
Installation Requirements/Conditions Number of trenches 1	
Septic Tank Size 1000 gallons Exact length of each tre	nch 180feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed	, 0
Maximum Trench Depth	of: 18-24 inches (Maximum soil cover shall not exceed
(Trench bottoms shall be	
in all directions)	and the second s
Pump Requirements:ft. TDH vsGPM	inches below pipe
1 00 10 00 000000	Aggregate Depth:inches above pipe
Conditions: Using existing Septic and Pump Tank	inches total
NATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PAR	T OF SEPTIC SYSTEM OR REPAIR AREA
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.	TOT SETTIC STSTEM ON NETAIN ANEA.
**If applicable: 1 understand the system type specified is different from the type	specified on the application. I accept the specifications of this permit.
	3
Owner/Legal Representative Signature:	Date:
this Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. Th	
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Tre-	atment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
K-11/1 / 11/	115
Authorized State Agent:	Date: <u>1/7/2020</u>
	Authorization Expiration Date: 1/7/2025

Application # EH2001-0002

Harnett County Department of Public Health Site Sketch

Property Location:	5 Senter Ln	13400	level		
Issued To: X Q Y F	helds	Subdivision	Senter Hills		Lot # <u>25</u>
Authorized State Agent:	BALO	LREHS		_ Date: _	1-7-2020



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.