

Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 133 Bayview Road (Neills Creek Road - SE ISSUED TO: Ron VanDyke SUBDIVISION South Creek NEW 🗍 REPAIR X EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Existing 4-BR SFD Proposed Wastewater System Type: 25% Reduction System Projected Daily Flow: 480 Number of bedrooms: 4 Number of Occupants: 8 Basement Yes X No Pump Required: XYes ☐ No May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well 50+ X Five years Permit valid for: Permit conditions: No expiration 16/2020 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Ron VanDyke PROPERTY LOCATION: 133 Bayview Road (Neills Creek Road -SUBDIVISION South Creek Facility Type: Existing 4-BR SFD □ New Expansion ✓ Repair Basement? Yes No Basement Fixtures? Yes Type of Wastewater System** Not Applicable (Initial) Wastewater Flow: 480 GPD (See note below, if applicable) Pump to 25% Reduction System (Repair) Installation Requirements/Conditions Number of trenches 3 Septic Tank Size Ext. gallons Exact length of each trench 90 Trench Spacing: 9 Feet on Center Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6-12 inches Maximum Trench Depth of: 18-24 (Maximum soil cover shall not exceed inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ____ ft. TDH vs. _ inches below pipe Aggregate Depth: NA inches above pipe Conditions: Pump to D-Box Equal Distribution Required; See Site plan inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: ____ Construction Authorization Expiration Date: 11/16/2025 ANDTHEW COMIN

Harnett County Department of Public Health Site Sketch

Property Location: 133 Bayview Road (Neills Creek Road - SR 1513)

Issued To: Ron VanDyke Subdivision South Creek

Authorized State Agent: Date: 1116 Jobbo

ANDREW COMIN

96' *MERT OSSITE PRIOR to INSTILL * 10 TO FALL TOTALL * 6IN FIRST 60 FT X DUMP TO D-BOX W/ EGULL SISTAIBUTICA MEGUINESS P PRECONSULT MEETING SFD - MAY TIE IN EXISTING SEPTIC ANEA P * UTILIZE TEXISTING TANK DIW TO ROMP TO NEAR 96'

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.