

February 14, 2020

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Harold Butts
2191 Keith Hills Road
Lillington NC 27546

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for 64 Samantha Avenue Angier, NC 27501

Mr. Butts:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Inspected on 2/13/2020. System showed no immediate signs of failure (surfacing, backing up, exposed system) but signs of system wear and tear. Drain lines had caused divots in ground and drain field was dry but showed presence of occasional wetness. Muddy spot was present at end of drain line but also area of what appears to be routine vehicular traffic. Septic tank outlet tee degraded and damaged with need for replacement. Inspection occurred during post-rain wet conditions. Owner requested to monitor system under dry conditions, prevent vehicular traffic over drain lines, and replace sanitary tee. Reconfirm with EH if system does not dry out, strong smells occur, or septic surfacing occurs.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting

strong roots • new growth