

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant: *Chapman*  
 Address:                      Date Evaluated:  
 Proposed Facility: *EX SFD*      Design Flow (.1949): *360*      Property Size:  
 Location of Site:              Property Recorded:  
 Water Supply:               Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1.	L	0-8	SL1	FLGWSNP					
		8-36	SL1M	VW <sup>min</sup> FLGWSBK	<i>2.5/31</i> <i>30-40"</i>				<i>.3 → .4</i>
		36+	SAP						
2	L	0-10	SL	FLGWSNP					
		10-40	SL1M	VW FLGWSBK	<i>46" S.R</i> <i>31.</i>				<i>.3 → .4</i>
		36+	SAP						

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>JN</i> Others Present: <i>AC</i>
Available Space (.1945)		<i>/</i>	
System Type(s)		<i>250/10</i>	
Site LTAR		<i>.3 → .4</i> <i>CLAY</i> <i>SAP</i>	

