

April 29, 2020

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Vonda Ferrell
2004 Meadow Court
Clayton, NC 27520

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for 1890 Clayhole Road Coats, NC 27521

Ms. Ferrell:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Onsite issues appears consistent with similar problems from 2018. Unable to locate soil suitable for conventional septic system repair. Owner is recommended to work with septic contractor/pumper and performed maintenance to see if existing system can perform normal (routine maintenance) as done in 2018. Advised owner to contact a soil scientist to see if there are any innovative septic system repair options or if any easements/re-combinations are possible on surrounding property owned by owner.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting