

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: RANDY & MARIA SNEDECKER PROPERTY LOCATION: 5631 CHRISTIAN LIGHT RD (S11412)
 SUBDIVISION _____ LOT # 1

NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: _____

Type of Structure: 3-BEDROOM EXT SID
 Proposed Wastewater System Type: 25% REDUCTION SYS.
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: Five years
 No expiration
 Permit conditions: _____

Authorized State Agent: [Signature] Date: 05/04/2020 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: RANDY & MARIA SNEDECKER PROPERTY LOCATION: 5631 CHRISTIAN LIGHT RD (S11412)
 SUBDIVISION _____ LOT # 1

Facility Type: 302 EXT SID New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Not Applicable (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable)

25% Reduction System (Repair)

Installation Requirements/Conditions	Number of trenches <u>3</u>	
Septic Tank Size <u>1000</u> gallons	Exact length of each trench <u>80</u> feet	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size _____ gallons	Trenches shall be installed on contour at a Maximum Trench Depth of: <u>20</u> inches (Trench bottoms shall be level to +/-1/4" in all directions)	Soil Cover: <u>8</u> inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: _____ ft. TDH vs. _____ GPM		Aggregate Depth: <u>NA</u> inches below pipe <u>NA</u> inches above pipe <u>NA</u> inches total
Conditions: <u>GRAVITY TO D-BOX EQUAL DISTRIBUTION</u>		

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 05/04/2020
ANDREW CURRIN Construction Authorization Expiration Date: 05/04/2025

Application # EH 2004-0019

Harnett County Department of Public Health Site Sketch


Property Location: 5631 CHRISTIAN LIGHT ROAD (S21412)

Issued To: RANDY + MARIA SNEDECKER Subdivision _____

Lot # 1

Authorized State Agent: _____

Date: 05/04/2020



- * GRAVITY TO D-BOX
EQUAL DISTRIBUTION
- * NEW TANK SHALL BE
PLACED DOWNSHILL
OR
EXT TANK FULLY UNCOVERED
W/ TANK INTEGRITY CHECKED,
BAFFLE WALL PRESENT, AND
SANITARY TEE PRESENT
- * IF ABANDONED EXT TANK
SHALL BE PUMPED, CRUSHED,
AND BACKFILLED ONSITE

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.