

May 15, 2020

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

May Janice Patterson
111 Rutledge Drive Apt 11
Salem, VA 24153

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 58 Sweet Jenny Lane Lillington, NC 27546

Ms. Patterson :

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other-No failure noted at time inspection on 5/12/2020. Tank empty. D-Box not backing up. No surfacing in yard. Provided septic report notes D-Box was not draining properly but that no maintenance was performed to alleviate failure. Maintenance advised (snaking, clearing out lines) if additional problems occur and/or display to Health Department presence of failure to issue repair permit.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting