

HTE #: BRES2005-0049

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Angelica Aviles Phone #: 919.368.3758

Address: 5961 Christian Light Rd. Fuquay-Varina, NC 27526

Name of Mobile Home Park or S/D: Not Applicable

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 5961 Christian Light Rd. (SR 1412)

Purpose of Inspection: 15'x30' Inground Pool - Approved with exception - Repair permit filed.
Septic system shall be replaced or maintenance completed to repair existing system.

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

06/12/2020

Date