Harnett County Department of Public Health

Improvement Permit


A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 1165 Darroch Rd (SR#1128)

ISSUED TO: Christopher Brown	SUBDIVISION	LOT #
NEW REPAIR EXPANSION Type of Structure: Existing SFD		equired prior to Construction Authorization Issuance:
Proposed Wastewater System Type: 25% Reduction		
Projected Daily Flow: 360 GPD		
Number of bedrooms: 3 Number of Occupants: 6	max	
Basement No		
Pump Required: Yes No May be required based on Type of Water Supply: Community Public Well	final location and elevations of facilities	D
Permit conditions:	Distance from well 301 feet	Permit valid for: ⊠ Five years No expiration
Fernit Conditions.		The state of the s
4161		
Authorized State Agent::	Date: 7/7/2020	SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Dep ferment in no way guarantees the issuance site is subject to revocation if the site plan, plat, or the intended use changes. The Impr	of other permits. The permit holder is responsible for convernent Permit shall not be affected by a change in own	necking with appropriate governing bodies in meeting their requirements. This
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.	orement remine shall not be anected by a change in on	tersing of the site. This permit is subject to compliance with the provisions of
Co	nstruction Authorization	
	(Required for Building Permit)	
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956 with the attached system layout.		s into this permit and shall be met. Systems shall be installed in accordance
ISSUED TO: Christopher Brown		Darroch Rd (SR#1128)
Facility Type: Existing SFD	New Expansion Repair	
Basement? X Yes No Basement Fixtures? X Y		
Type of Wastewater System** 25% Reduction	I NO	(Initial) Wastewater Flow: 360 GPD
(See note below, if applicable ())		(IIIIIai) Wastewater 110W. 500 GFD
0=0/ == 1	(Repair)	
	trenches 1	
· 보통하다 경험 경험 경험 경험 등 전 하다 있는 것도 보고 있다. 그는 그 그 그 그 그 그 그 그 그 그 그 그 그 그 그 그 그 그	th of each trench 230 feet	Trench Spacing: 9 Feet on Center
	nall be installed on contour at a	Soil Cover: 6inches
,	Trench Depth of: 18 inches	(Maximum soil cover shall not exceed
	ttoms shall be level to +/-1/4"	36" above the trench bottom)
in all direc		,
Pump Requirements:ft. TDH vsGPM		inches below pipe
		Aggregate Depth: inches above pipe
Conditions:		inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FR	OM ANY PART OF SEPTIC SYSTEM OR	REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD	AREA.	
**If applicable: 1 understand the system type specified is different	from the type specified on the application	a I accent the specifications of this permit
wappicaote. 2 onocisiano in system type specimeo is unicient	nom the type specified on the application	. Taccept the specimeations of this perimit.
Owner/Legal Representative Signature:		Date:
This Construction Authorization is subject to revocation if the site plan, plat, or the intend	ed use changes. The Construction Authorization shall not	be transferred when there is a change in ownership of the site. This
Construction Authorization is subject to compliance with the provisions of the Laws and Ri	les for Sewage Treatment and Disposal and to the condi	ions of this permit. SEE ATTACHED SITE SKETCH
24111	5000	
Authorized State Agent:		7/7/2020
	Construction Authorization Expiration 1	Date: 8/18/2020
	1	

Harnett County Department of Public Health Site Sketch

Property Location: 1165 Dayoc	an Rd, Cillination	(SR# 1128)	
Issued To: Christopher Brow	Subdivision		Lot #
Authorized State Agent:	all REHS-I	Date: 7	7/2020



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.