

September 18, 2020

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Timothy Deranek
400 Wyndham Place
Fuquay-Varina NC 27526

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for 400 Wyndham Place, Fuquay-Varina NC 27526

Mr. Deranek:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required

7. Other- Drain line appears to have obstructions inhibiting flow of septic affluent. Septic affluent surfacing at D-Box but no surfacing along two (2) 150ft drain lines. Multiple trees with roots along drain line route. Snake out or camera drain lines and attempt clearing out blockages. Contact septic contractor to inspect for blockage.

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting
Enclosures