

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
307 W. CORNELIUS HARNETT BLVD.
LILLINGTON, NC 27546
910-893-7547 PHONE
910-893-9371 FAX

Application for Repair

EMAIL ADDRESS: Hwilliams79@gmail.com

NAME Travis Williams PHONE NUMBER 910 635 9648

PHYSICAL ADDRESS 275 Gold Ct Broadway NC 27505

MAILING ADDRESS (IF DIFFERENT THAN PHYSICAL) _____

IF RENTING, LEASING, ETC., LIST PROPERTY OWNER NAME _____

SUBDIVISION NAME	LOT #/TRACT #	STATE RD/HWY	SIZE OF LOT/TRACT
<u>Blue Tingen Point</u>		<u>27</u>	<u>.65</u>

Type of Dwelling: Modular Mobile Home Stick built Other _____

Number of bedrooms 3 Basement

Garage: Yes No Dishwasher: Yes No Garbage Disposal: Yes No

Water Supply: Private Well Community System County

Directions from Lillington to your site: 2 miles past Western Harnett Highschool on the left
between Docs Rd and Tingen Rd. If you get to (R) at Buffalo Lk Rd
you went too far

In order for Environmental Health to help you with your repair, you will need to comply by completing the following:

1. A "surveyed and recorded map" and "deed to your property" must be attached to this application. Please inform us of any wells on the property by showing on your survey map.
2. The outlet end of the tank and the distribution box will need to be uncovered and property lines flagged. After the tank is uncovered, property lines flagged, underground utilities marked, and the orange sign has been placed, you will need to call us at 910-893-7547 to confirm that your site is ready for evaluation.

Your system must be repaired within 30 days of issuance of the Improvement Permit or the time set within receipt of a violation letter. (Whichever is applicable.)

By signing below, I certify that all of the above information is correct to the best of my knowledge. False information will result in the denial of the permit. The permit is subject to revocation if the site plan, intended use, or ownership changes.

Travis Williams
Signature

9 Oct 2020
Date

HOMEOWNER INTERVIEW FORM

It is important that you answer the following questions for our inspectors. Please do not leave any blanks if possible, and answer all questions to the best of your ability. Thank You.

Have you received a violation letter for a failing system from our office? YES NO

Also, within the last 5 years have you completed an application for repair for this site? YES NO

Year home was built (or year of septic tank installation) 2010

Installer of system _____

Septic Tank Pumper _____

Designer of System _____

1. Number of people who live in house? 3 # adults 1 # children _____ # total
2. What is your average estimated daily water usage? _____ gallons/month or day _____ county water. If HCPU please give the name the bill is listed in Travis Lee Williams
3. If you have a garbage disposal, how often is it used? daily weekly monthly
4. When was the septic tank last pumped? 1yr How often do you have it pumped? 3yr
5. If you have a dishwasher, how often do you use it? daily every other day weekly
6. If you have a washing machine, how often do you use it? daily every other day weekly monthly
7. Do you have a water softener or treatment system? YES NO Where does it drain?

8. Do you use an "in tank" toilet bowl sanitizer? YES NO
9. Are you or any member in your household using long term prescription drugs, antibiotics or chemotherapy? YES NO If yes please list _____
10. Do you put household cleaning chemicals down the drain? YES NO If so, what kind?

11. Have you put any chemicals (paints, thinners, etc.) down the drain? YES NO
12. Have you installed any water fixtures since your system has been installed? YES NO If yes, please list any additions including any spas, whirlpool, sinks, lavatories, bath/showers, toilets _____
13. Do you have an underground lawn watering system? YES NO
14. Has any work been done to your structure since the initial move into your home such as, a roof, gutter drains, basement foundation drains, landscaping, etc? If yes, please list Subsurface drain, gutter drains
15. Are there any underground utilities on your lot? Please check all that apply:
 Power Phone Cable Gas Water
16. Describe what is happening when you are having problems with your septic system, and when was this first noticed?
Water comes out the ground at end of septic line. ~~10~~ 7 yrs ago
17. Do you notice the problem as being patterned or linked to a specific event (i.e., wash clothes, heavy rains, and household guests?) YES NO If Yes, please list heavy rain, clothes washing, ~~house guests~~

HTE# 10-5-24935

Harnett County Department of Public Health

PERMIT # 26244

Operation Permit

21754

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: HWY 27 W

Name: (owner) WYNN CONSTRUCTION INC SUBDIVISION TINGEN POINTE LOT # 102

System Installer: THORNTONS PLUMBING Registration # _____

Basement with plumbing: Garage Number of Bedrooms 3


Type of Water Supply: Community Public Well Distance from well 100 feet

System Type: IIIg Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No
If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____
V. Other: _____

D-Box Pump Alarm H2O Line PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other EZ FLOW Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 60 feet width of ditches 3 feet depth of ditches 12 inches

French Drain Required: _____ Linear feet

Authorized State Agent [Signature] Date 10/15/18

COMMENTS:

SITE VISIT ON 3/17/14 - OT - BM

SYSTEM BLOWING OUT. D-BOX OPENED. CLEAR
WATER RUNNING INTO BOX FROM TOP LINE. BOTTOM
2 LINES BLOWING OUT. RECOMMENDED FRENCH
DRAIN TO CATCH LATERAL WATER MOVEMENT.
SEE SKETCH ON OP.

HTE# 10-5-24935

Harnett County Department of Public Health

PERMIT # 26244

Operation Permit

21754

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: HWY 27 W

Name: (owner) WYNN CONSTRUCTION INC SUBDIVISION TINGER POINTE LOT # 102

System Installer: THORNTONS PLUMBING Registration # _____


Basement with plumbing: Garage Number of Bedrooms 3

Type of Water Supply: Community Public Well Distance from well 100 feet

System Type: IIIg Types V and VI Systems expire in 5 years.

(In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No
If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____

V. Other: _____

D-Box Pump Alarm H2O Line PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other EZ Flow Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field: No. of ditches 4 exact length of each ditch 60 feet width of ditches 3 feet depth of ditches 18 inches

French Drain Required: _____ Linear feet

Authorized State Agent [Signature] Date 10/15/18

PLAT NORTH
PC D
SLIDE 3-B

-- SETBACKS --
FRONT=35'
REAR=25'
SIDE YARD=10'
CORNER SIDE YARD=20'

-- AREA SUMMARY --
LOTS 87-113
18,444 ACRES
803,424 SQ. FEET

GOLD COURT
1.772 ACRES
77,192 SQ. FEET

OMAHA DRIVE
0.424 ACRES
18,475 SQ. FEET

-- TOTAL AREA --
22.065 ACRES
961,131 SQ. FEET

N/F
LOT 4
VIRGINIA BLALOCK HICKS PROPERTY
PC D, SLIDE 3-B
HARNETT COUNTY REGISTER
OF DEEDS
ZONE: RA-20R

-- DEVELOPMENT REVIEW BOARD --


I HEREBY CERTIFY THAT THE DEVELOPMENT DEPICTED
HEREON HAS BEEN GRANTED FINAL APPROVAL BY
THE HARNETT COUNTY DEVELOPMENT REVIEW BOARD
PURSUANT TO THE REGULATIONS SET FORTH BY E-911
ADDRESSING, ENVIRONMENTAL HEALTH, FIRE MARSHAL,
PLANNING AND PUBLIC UTILITIES OF HARNETT COUNTY,
N.C., SUBJECT TO RECORDATION IN HARNETT COUNTY
OFFICE OF REGISTER OF DEEDS WITHIN THIRTY DAYS
OF THE DATE BELOW.

DEVELOPMENT REVIEW BOARD, CHAIRMAN

DATE

1-20-10

-- REVIEW CERTIFICATION --





FOR REGISTRATION REGISTER OF DEEDS
KIMBERLY S. HARGROVE
HARNETT COUNTY, NC
2010 NOV 23 04:26:29 PM
BK:2809 PG:693-695 FEE:\$22.00
NC REV STAMP:\$320.00
INSTRUMENT # 2010016941

HARNETT COUNTY TAX ID#
03.9576-01.0088-06

11-23-10 BY SB

Revenue: \$320.00

Tax #:

Prepared By: Nathan M. Garren, a licensed North Carolina attorney. Delinquent taxes, if any to be paid by the closing attorney to the tax collector upon disbursement of closing proceeds.

Mail To: Grantee

STATE OF NORTH CAROLINA

GENERAL WARRANTY DEED

COUNTY OF HARNETT

THIS DEED, made this 28th day of October, 2010, by and between WYNN CONSTRUCTION, INC. (hereinafter "Grantor") with a mailing address of 2550 Capitol Drive, Suite 105, Creedmoor, NC 27522 and TRAVIS L. WILLIAMS and SHANNON M. WILLIAMS, husband and wife (hereinafter "Grantees") with a mailing address of 225 Gold Court, Broadway, NC 27505.

WITNESSETH:

THAT Grantor in consideration of Ten Dollars (\$10.00) and other valuable consideration to it paid by Grantees, the receipt of which is hereby acknowledged, has and by these presents does grant, bargain, sell and convey, unto Grantees, their successors, heirs and assigns, all of its interest in that certain tract or parcel of land located in Harnett County and described as being all of Lot 102, containing 0.651 acres, more or less, Tingen Pointe Subdivision, as shown on the plat entitled "Final Subdivision Plat of Tingen Pointe Subdivision - Phase 3B," by the Chandler Group, dated December 15, 2009 and recorded in Book of Maps 2010, at Pages 43 and 44, Harnett County Register of Deeds, reference to which is hereby made for a more complete and accurate description. See Deed Book 2796, Page 831, Harnett County Registry for further reference. The property being conveyed is not the primary residence of the Grantor.

TO HAVE AND TO HOLD the said land, together with all privileges and appurtenances as thereunto belonging unto the said Grantees in fee simple.

And the Grantor covenants with the Grantee, that the Grantor is seized of the premises in fee simple, has the right to convey the same in fee simple, that title is marketable and free and clear of all encumbrances, and that Grantor will warrant and defend the title against the lawful claims of all persons whomsoever except for the exceptions hereinafter stated.

Title to the property hereinabove described is subject to the following exceptions:

1. Ad Valorem taxes for the year 2010 and thereafter.
2. Restrictive covenants and easements of record.

IN WITNESS WHEREOF, the Grantor has caused this instrument to be signed in its corporate name by its duly authorized officer the day and year first above written.

Wynn Construction, Inc.

By: Nancy R. Wynn (SEAL)
Nancy R. Wynn, Vice President

STATE OF NORTH CAROLINA
COUNTY OF GRANVILLE

I, Nathan M. Garren, a Notary Public, for the County of Granville, State of North Carolina do hereby certify that Nancy R. Wynn, Vice President of Crosswind Development, Inc., a North Carolina corporation, personally appeared before me this day and, for and on behalf of said corporation, acknowledged the execution of the foregoing instrument.

Witness my hand and official stamp or seal this 28th day of October, 2010.

My Commission Expires: October 8, 2012

