

Harnett County Department of Public Health

PERMIT # EH2016-002

Operation Permit

- RELOCATION
- New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: 5155 FAIRGROUND RD (SL 1705)

Name: (owner) WALLEN REALTY SUBDIVISION _____ LOT # _____

System Installer: CHARLES GARBOUR

Basement with plumbing: Garage Number of Bedrooms 3


Type of Water Supply: Community Public Well Distance from well NA feet

System Type: 2570 REDUCTION SIS, IIIg Types V and VI Systems expire in 5 years.

(In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

- * WATER LINE RELOCATED DOWN D/W AND AROUND (10FT+ MIN)
- * RELOCATED PLUMBING TO FRONT
- * PROPOSAL BY ADAMS SOIL CONSULTING
- * OLD WELL ABANDONED
- * PROPERTY LINE BASED OFF PROPOSED/UNDEEDED/UNAPPROVED SURVEY



- * INSTALLED 26 IN DEEP TO SHALLOW 18 IN W/ STEPDOWN
- * 15'+ POWER SETBACK
- * 80 FT TO STEPDOWN TO FINAL 35 FT [BOTH LINES]

PERMIT CONDITIONS:

- FAIRGROUND ROAD (SL 1705)
- I. Performance: System shall perform in accordance with Rule .1961.
 - II. Monitoring: As required by Rule .1961.
 - III. Maintenance: As required by Rule .1961. Other: _____
 Subsurface system operator required? Yes No
 If yes, see attached sheet for additional operation conditions, maintenance and reporting.
 - IV. Operation: _____
 - V. Other: _____

- _____ D-Box _____ Pump _____ Alarm _____ H2O Line _____ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other FE FLOW IIIg Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of exact length width of depth of
 Drainage Field ditches 2 of each ditch 115 feet ditches 3 feet ditches 26-18 inches
 French Drain Required: _____ Linear feet

Authorized State Agent [Signature] Date 04/15/2021