

November 20, 2020

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Carolyn Collins
26 East Paige Wynd Drive
Angier NC 27501

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 794 Maynard Lake Road Erwin, NC 28339

Ms. Collins:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other- Refer to contractor for routine maintenance. No failure was noted at the time of inspection. Drain line area dry. Tank could not be inspected do to lid size. Owner advised via phone to contact a septic contractor to review plumbing line from house for blockages, inspect tank to ensure sanitary tee is intact and tank intact, inspect supply line to tank, unconvex D-box and inspect, and inspect two (2) 45ft ezflow lines for performance and any blockages. Lines were replaced in 2004. Owner advised to exhaust opportunities for general maintenance in advance of repair due to likely need to pump system to front yard.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting
Enclosures