

SFD1911-0045

Harnett County Department of Public Health

PERMIT # EH2101-00212

Operation Permit

821429

New Installation Septic Tank Nitrification Line Repair Expansion

JESUS ROMERO

PROPERTY LOCATION: 169 OLD HEAD WAY (CHAYBEATE ROAD)

Name: (owner) LGI HOMES NC LLC SUBDIVISION AURAY POND PHASE LOT # 87

System Installer: THORNTONS PLUMBING

Basement with plumbing: Garage Number of Bedrooms 3

Type of Water Supply: Community Public Well Distance from well NA feet


System Type: 2% REDUCTION SYS. IIIg Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

* GRAVITY TO D-BOX EQUAL DISTRIBUTION
 * ORIGINAL INSTALL: 04/27/2020
 * TRADITIONAL FRENCH DRAIN [NO PLASTIC LINED] INSTALLED 04/09/2021
 * ADDED ONE (1) 8"FT LINE TO RELIEVE EXT SYSTEM [WET SPOT LINE 2 @ CORNER] 06/08/2022
 * ALL BUTTER @ 12" AND FOUNDATION DRAIN PIPED BY BUILDER TO 12" GRM



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .196.
- II. Monitoring: As required by Rule .196.
- III. Maintenance: As required by Rule .196. Other: OLD HEAD WLL
 Subsurface system operator required? Yes No
 If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____
 V. Other: _____

D-Box Pump Alarm H2O Line PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other EXT FLOW IIIg Septic Tank: 1000 (EXT) gallons Pump Tank: _____ gallons
 Subsurface No. of 115 (2 - EXT) exact length 2 (EXT) width of _____ depth of _____
 Drainage Field ditches 85 (NEW) of each ditch 1 (NEW) feet ditches 3 feet ditches 18 inches
 French Drain Required: _____ Linear feet

Authorized State Agent [Signature] Date 06/08/2022