

# Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 1415 LAFAYETTE ROAD (521443)  
 SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_  
 ISSUED TO: JEFFREY JOHNSON  
 NEW  REPAIR  EXPANSION   
 Type of Structure: AGRI-TOURISM BARN  
 Proposed Wastewater System Type: 25% REDUCTION/CONVENTIONAL  
 Projected Daily Flow: \_\_\_\_\_ GPD  
 Number of bedrooms: NA Number of Occupants: NA max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well 50+ feet [FOUNTE] Permit valid for:  Five years  No expiration  
 Permit conditions: \_\_\_\_\_

Authorized State Agent: [Signature] Date: 03/04/2021 SEE ATTACHED SITE SKETCH  
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization (Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: JEFFREY JOHNSON PROPERTY LOCATION: 1415 LAFAYETTE RD (521443)  
 SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_  
 Facility Type: AGRI-TOURISM BARN  New  Expansion  Repair  
 Basement?  Yes  No Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* PUMP TO 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 400 GPD  
 (See note below, if applicable   
PUMP TO 25% REDUCTION (Repair)

**Installation Requirements/Conditions**  
 Septic Tank Size 1250 gallons Number of trenches 3  
 Pump Tank Size 1000 gallons Exact length of each trench 100 feet  
 Trenches shall be installed on contour at a Trench Spacing: NA Feet on Center  
 Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)  
 (Trench bottoms shall be level to +/-1/4" in all directions)  
 Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: NA inches below pipe  
NA inches above pipe  
NA inches total  
 Conditions: SEE SITE PLAN

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 03/04/2021  
ANDREW CORBIN Construction Authorization Expiration Date: 03/04/2026

Application # EH 2102-0010

### Harnett County Department of Public Health Site Sketch

Property Location: 1415 LAFAYETTE ROAD (SL 1443)

Issued To: JEFFERY JOHNSON Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_

Authorized State Agent: *Andrew Curran* Date: 03/04/2021  
ANDREW CURRAN

\* SUPPLY LINE MAY BE  
ROOTED UNDER EXT  
WATER LINE W/ 18IN  
MIN SEPERATION  
[DEEP SUPPLY LINE]  
\* ANY FUTURE WELL  
SHALL BE 50FT  
SEPERATION FROM  
ANY SEPTIC COMPONENT

- \* AGRU - TOURISM ONLY - NOT SIZED FOR RESTAURANT  
OR FOOD PRODUCTION SITE
- \* AGRICULTURAL BARN W/ SINGLE EXTERIOR BATHROOM  
SIZED FOR 250 GPD MAX AND SIX (6) EMPLOYEES  
@ 25 GPD PER EMPLOYEE = 400 GPD MAX
- \* 300FT 25% REDUCTION OR 400FT GRAVEL SIS.
- \* PUMP TO MEDIUM D-BOX W/ EQUAL DISTRIBUTION REQUIRED
- \* 18IN MAX
- \* SEPTIC FIELD SHALL BE PROTECTED FROM TRAFFIC  
AND AGRICULTURAL FIELD USAGE



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.

## Andrew Currin

---

**From:** jrjwjohnson@yahoo.com  
**Sent:** Monday, March 1, 2021 8:22 AM  
**To:** Andrew Currin  
**Subject:** Johnson 1415 Lafayette

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good Morning, just following up with the statement that we will have one bathroom for 5 employees on the farm at 1415 Lafayette Road shop. Let me know if you need anything further.

Jeff Johnson  
919-723-6611

Johnson Shop (Farm)  
1415 Lafayette Rd.  
Fugway - Varina

EH 2102-0010



Re send to  
Andrew @ EHOFFICE  
Curin  
He is coming  
Back out this  
Friday  
2/26

Repair Area

Future  
Agriculture  
Events