

EH2102-0010

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: - Applicant: JEREMY JOHNSON
 Address: 1415 LAFAYETTE RD Date Evaluated: 02/24/2021
 Proposed Facility: Design Flow (.1949): TBD
 Location of Site: BLDG Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

Property Size:

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz		
1,2	L 5%	0-28	CL LS	HY NSM						
		28-48	M SIL	FZ SSS	7.5% clay, @ 42"	48			UNS / 0.4	
			PHYSICAL WETNESS [SEVERE] BTW TRANSITION [41IN-36IN], SOIL WAS DRY ABOVE AND BELOW. AUGER HOLE FILLED W/ WET SAND DRILLING + AFTER EQUAL TO BTW 41IN AND 22IN OF SURFACE							
3,4,5,6	L 3%	0-28	CL LS	HY NSM					PS	
		28-48	M SIL	FZ SSS		48			0.4	
			PHYSICAL WETNESS [SEVERE] BTW TRANSITION [41IN-38IN] SOIL DRY ABOVE AND BELOW. AUGER HOLE FILLED W/ WET SAND DURING AND AFTER EQUAL TO BTW 34IN AND 38IN OF SURFACE							
			* CURTAIN MAY BE REQUIRED - EQUAL UNDER WET CONDITIONS							

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): <u>PROVISIONALLY SUITABLE</u>
System Type(s)	<u>25/0 MED</u>	<u>25/0 MED</u>	Evaluated By: <u>ANDREW CURRAN, REHS</u>
Site LTAR	<u>0.4</u>	<u>0.4</u>	Others Present:

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM		SP-SLIGHTLY STICKY	
CC-CONCLAVE SLOPE		CL-CLAY LOAM		P-PLASTIC	
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM		VP-VERY PLASTIC	
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE

- SG-SINGLE GRAIN
- M- MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

