

February 15, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Raymond McNemar
626 Tylerstone Drive
Fuquay-Varina NC 27526

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 626 Tylerstone Drive, Fuquay-Varina NC 27526

Mr. McNemar:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Surfacing present at what appears to be the end of 2 Lines. Ownership advised to do routine septic system maintenance (pump) and inspect tank, uncover and inspect D-Box, and snake or camera drain line for any obstruction in flow) prior to going down adding drain line. Review system for root intrusion. Lot appears to have available space and soil to add drain line if required.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting
Enclosures