

# HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH Well Abandonment Permit

Application Number: EH2102-0018 & EH2010-0012

Applicant Name: Warren Realty LLC

Address: 5155 Fairground Road Dunn, NC 28334

Type of Well: Hand Dug Total Depth: 22ft Diameter: 24-26in Grouted: No Static Water Level: 14ft

Directions to Site: 5155 Fairground Road Dunn, NC 28334

Agent of the State




Date:

02/22/2021

Abandonment Procedure: Abandonment Procedure: 1. Remove all plumbing or piping into the well, along with any obstructions inside the well; 2. Remove as much of the well tile casing as possible, but no less than to a depth of three feet below land surface; 3. remove all soil or other subsurface material present down to the top of the remaining well casing, and extending to a width of at least 12 inches outside of the well casing on all sides; 4. Fill the well up to the top of the remaining casing with cement grout, concrete grout, bentonite grout, dry clay, or material excavated during drilling of the well and then compacted in place; 5. Pour a one foot thick concrete grout or cement grout plug that fills the entire excavated area about the top of the casing, including the area extending on all sides of the casing out to a width of at least 12 inches on all sides; 6. Complete the abandonment process by filling the remainder of the well above the concrete or cement plug with additional concrete grout, cement grout, or soil. A record of the abandonment must be submitted within 30 days of abandonment.

Note: Contact Harnett County Environmental Health for appointment prior to beginning of well abandonment procedure.

Well must be abandoned by a Certified North Carolina well driller/contractor.



Louy Sanderson Tte  
Property Owner's or Owners Legal Representative Signature Required

02/23/2021  
Date