

March 18, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

David Strickland
459 Neighbors Road
Dunn, NC 28334

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 459 Neighbors Road Dunn, NC 28334

Mr. Strickland:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- System maintenance advised. Advised to work with Certified Septic Contractor to review and inspect full condition of septic system. System appears to likely have drain line blockages. Advised to snake or camera drain line and repair any blockages present. Advised to exhaust all maintenance possibilities in advance of system replacement. Repair drain line will be unorthodox and unconventional.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting
Enclosures