

Harnett County Department of Public Health

Improvement Permit

Paul Tarbox

A building permit cannot be issued with only an Improvement Permit

ISSUED TO:

Bart Durham

PROPERTY LOCATION: SR1006 OLD STAGE RD

SUBDIVISION: OXFORD WOODS

LOT # 34

NEW

REPAIR

EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure:

EX SFD

Proposed Wastewater System Type:

25% REDUCTION

Projected Daily Flow:

360

GPD

Number of bedrooms:

3

Number of Occupants:

6

max

Basement Yes

No

Pump Required:

Yes

No

May be required based on final location and elevations of facilities

Type of Water Supply:

Community

Public

Well

Distance from well _____ feet

Permit valid for:

Five years

No expiration

Authorized State Agent:

James E. Markham III

Date:

3-30-21

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO:

Paul Tarbox
Bart Durham

PROPERTY LOCATION: SR1006 OLD STAGE RD

SUBDIVISION: OXFORD WOODS

LOT # 34

Facility Type:

EX SFD

New

Expansion

Repair

Basement? Yes

No

Basement Fixtures? Yes

No

Type of Wastewater System**

25% REDUCTION

(Repair)

(Initial) Wastewater Flow:

360

GPD

(See note below, if applicable)

Installation Requirements/Conditions

Septic Tank Size EX gallons

Pump Tank Size EX gallons

Number of trenches 3

Exact length of each trench 75 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 24 MAX inches

(Trench bottoms shall be level to +/-1/4"

in all directions)

Trench Spacing: 9 Feet on Center

Soil Cover: 6 inches

(Maximum soil cover shall not exceed

36" above the trench bottom)

Pump Requirements:

_____ ft. TDH vs. _____ GPM

Contractor to meet on site prior to install.

Aggregate Depth: 6 inches below pipe

2 inches above pipe

Conditions:

French Drains Required First, then drain lines to BG AREA IF DRAINS DO NOT FIX

12 inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.

NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This

Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent:

James E. Markham III


Date: 3-30-21

Construction Authorization Expiration Date: 3-30-26

Application # EH 2103-0017

Harnett County Department of Public Health Site Sketch

Property Location: JR1006 OLD STAGE RD
Issued To: Bart Dunham Subdivision OXFORD WOODS Lot # 34
Authorized State Agent: Paul Jarboe James E. Mandala Date: 3-30-21



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.