

May 13, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

David Langdon
64 Rainbow Drive
Erwin, NC 28339

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 64 Rainbow Drive Erwin, NC 28339

Mr. Langdon:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Septic System Maintenance Advised - Onsite evaluation showed lot soil was suitable for potential new septic placement. Existing tank has been pumped recently but no maintenance done to inspect condition of tank or possible cause of failure. Tank is filling up but not backing up into house at time of inspection. Owner is advised repair could be issued but would likely require property irons located and vegetative overgrowth cleared out to design/permit system. Owner advised to have a routine inspection of septic system (uncovering tank, locating distribution method, checking for blockages/crashes, etc.) prior to proceeding. Reconfirm or coordinate with Environmental Health after inspection.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting

strong roots • new growth