

www.harnett.org

June 1, 2021

Harnett County Government Complex 307 W. Cornelius Harnett Boulevard Lillington, NC 27546

> ph: 910-893-7547 fax: 910-893-9371

Fabian Cunha 201 N Aiken Street Fuquay-Varina, NC 27526

Re: Status of Repair Permit for: 1434 Main Street Lillington, NC 27546

Mr. Cunha:
An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.
1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
2. Use orange flags to mark house corners (\$25.00 fee incurred)
3. Directions not clear to property (\$25.00 fee incurred)
4. Property needs <u>only</u> brush or vegetation removed
5. Driveway not shown on site plan
6. Backhoe pits required
X 7. Other- Onsite Evaluation showed older home recently remodeled with older tank in side yard. Tank appeared structurally sound with no signs of failure. Tank had been pumped but no flagging in septic area nor any signs of System Maintenance. Phone conversation revealed a plumber told him the septic system was too old. Owner could not verify it had been reviewed by a septic contractor. Owner advised system is to be reviewed by a septic contractor, report or documentation provided, and signs of failure displayed in the field. Should owner want new system owner without showing or providing signs of failure, a system relocation application and applicable fee will need to be filed with Harnett County Central Permitting. Repair: Should repair be required, a Duke Power ESMT runs right b/h SFD. Only front and side can be
used without nower assement documentation crossing granted. Likely renair area will include numping

used without power easement documentation crossing granted. Likely repair area will include pumping across driveway to open area or clearing trees out in front yard.

Your application will be put on hold until the selected items above have been addressed. When completed please call 910-893-7547 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Andrew Currin, R.E.H.S.

Environmental Health Specialist

Harnett County Department of Public Health

AC/slc