

Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Nancy R. Silvers PROPERTY LOCATION: 501532604 RD
 NEW REPAIR EXPANSION SUBDIVISION: Crossing MHP LOT # 22
 Type of Structure: Ex SWMT+SIOT Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: TANK
 Projected Daily Flow: 240 GPD
 Number of bedrooms: 2 Number of Occupants: 4 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: James E. Marshall JR RBAS Date: 6-24-21 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Nancy R. Silvers PROPERTY LOCATION: 501532604 RD
 Facility Type: Ex SWMT+SIOT New Expansion Repair SUBDIVISION: Crossing MHP LOT # 22
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** _____ (Initial) Wastewater Flow: 240 GPD
 (See note below, if applicable)

TANK (Repair)

Installation Requirements/Conditions	Number of trenches _____	Trench Spacing: _____ Feet on Center
Septic Tank Size <u>1000</u> gallons	Exact length of each trench _____ feet	Soil Cover: _____ inches
Pump Tank Size _____ gallons	Trenches shall be installed on contour at a	(Maximum soil cover shall not exceed
	Maximum Trench Depth of: _____ inches	36" above the trench bottom)
	(Trench bottoms shall be level to +/-1/4"	
	in all directions)	
Pump Requirements: _____ ft. TDH vs. _____ GPM		_____ inches below pipe
		Aggregate Depth: _____ inches above pipe
Conditions: <u>TANK ONLY</u>		_____ inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Marshall JR RBAS Date: 6-24-21
 Construction Authorization Expiration Date: 6-24-26

Application # EA2006-0013

Harnett County Department of Public Health Site Sketch

Property Location: 201532 604 RD


Issued To: Nancy R Selvens

Subdivision Crossing MHP

Lot # 22

Authorized State Agent: James E. Marshall III PHS

Date: 6-24-21



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.