

# CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT


Name: (owner) Calvin Myatt  New Installation  Septic Tank  
Property Location: SR# 1532  Repairs  Nitrification Line  
Subdivision Crossing MAP Lot # 22  
TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Contractor: CAG FARMS Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface Drainage Field No. of ditches 2 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18-24 in.  
French Drain: — Linear feet

PERMIT NO. 09971 Date: 1-13-95  
Inspected by: James E. Manly  
Environmental Health Specialist



# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) CALVIN MYATT  New Installation  Septic Tank  
Property Location: SR# 1532  Repairs  Nitrification Line

Subdivision Crossing MHP Lot # 22

Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: 82 X 131

Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface Drainage Field: No. of ditches 2 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18-24 in.  
French Drain required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site plans or intended use change. Date: 9-30-94  
Signed: James E. Mandak  
Environmental Health Specialist

VOID AFTER 5 YEARS STREET

