

Harnett County Department of Public Health

PERMIT # EH 2107-0010

Operation Permit

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: 521437 Balland Rd

Name: (owner) Lois J Seaverson SUBDIVISION Balland Woods LOT # 25

System Installer: Processor Septic


Basement with plumbing: Garage Number of Bedrooms 3

Type of Water Supply: Community Public Well Distance from well _____ feet

System Type: Fix Existing Stepdown Types V and VI Systems expire in 5 years.

(In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No
If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: _____
- V. Other: _____

_____ D-Box _____ Pump _____ Alarm _____ H2O Line _____ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other STEPDOWN ONLY Septic Tank: EX gallons Pump Tank: - gallons
Subsurface No. of exact length width of depth of
Drainage Field ditches EX of each ditch EX feet ditches EX feet ditches EX inches
French Drain Required: _____ Linear feet

Authorized State Agent James E. Markham Date 8-5-21