The North Carolina Administrative Code requires applications for septic permits to be signed by the owner of the property to be evaluated or by the owner's legal representative. Applications submitted by an owner's legal representative must include this completed and signed document. Please note that the person named the legal representative on this document must make the application. The signature of the person named the legal representative on this document must also appear at the bottom of this document.

I,	Robert Surles		, hereby authorize	
	(property owner's full name) John Roberts			
	legal representative's fu	II name)	to serve as my legal	
representativ	ve for submitting an applica	ation for an evaluation	on by the HARNETT	
County Heal	th Department of property	owned by me for the	purpose of obtaining	
a permit to ir	nstall, repair or expand an	on-site wastewater s	system. I understand	
that submitta	al of the application for eva	luation also authoriz	es the HARNETT	
County Heal	th Department to perform	said evaluation on m	y property.	
Property Ov	vner's Address:	C 210 N Angier, NC 2	7501	
Property Ov	vner's Phone: 919-639-4	1766		
Parcel Ident	ification Number (PIN):	0673-14-0317.000	7	
Parcel Size:	5.00	Parcel Location	on: 7411 NC 210 N	
			Angier, NC 27501	
Signature: _	Robert Syl	Date	4/16/21	
Signature: _	(property owner's full	name) Date:	0/2/2021	



Initial Application Date:	Application #			
			CU#	
Central Permitting 420 McKinne		RESIDENTIAL LAND USE APPLIC Phone: (910) 893-7525 ext:1		www.harnett.org/permits
A RECORDED SURVEY MAP, RE	CORDED DEED (OR OFFER TO PU	RCHASE) & SITE PLAN ARE REQUIRED	WHEN SUBMITTING A LA	ND USE APPLICATION
LANDOWNER: Robert Surles		Mailing Address:7411 NC 2	10 N	
	State:NCZip:27501	Contact No: 919-639-4766	Email:none	
APPLICANT*: John Roberts	Mailing Add	dress:1302 Roberts Road		
City: Newport	State: NC Zip: 28570		Email: john.robert	s@groundtruthsoil.com
*Please fill out applicant information if different		0672 14 0217 0	100	
ADDRESS: 7411 NC 210 N Angier, NO		PIN:0673-14-0317.0		
Zoning: Flood:	_ Watershed: De	ed Book / Page:		
Setbacks - Front: Back:	Side: Corner:			
PROPOSED USE:				
☐ SFD: (Size <u>50 x</u> 70) # Bedroo	oms: 3 # Baths: 2 Basemer	nt(w/wo bath): <u> n </u> Garage: <u> ^y </u> De	eck: <u> </u>	Monolithic y Slab: n Slab: n
TOTAL HTD SQ FT 3000GARAGE SQ	FT 500 (Is the bonus room	finished? () yes () no w/ac	loset? () yes () no	(if yes add in with # bedrooms
D. Madulay (Cina) # Daa	duaranta # Datha Daga		Cita Duilt Daalu	On France O# France
☐ Modular: (Sizex) # Bec TOTAL HTD SQ FT				
TOMETHE OUT I			ene sam adamente. (_	
☐ Manufactured Home:SW[DWTW (Sizex) # Bedrooms: Garage:	_(site built?) Deck:	(site built?)
☐ Duplex: (Sizex) No. Bu	ıildings:No.	Bedrooms Per Unit:	TOTAL HTD S	SQ FT
☐ Home Occupation: # Rooms:	Use:	Hours of Operation:		#Employees:
☐ Addition/Accessory/Other: (Size	v \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \		Closets in a	addition? () year () no
			Closets III a	dution: () yes () no
TOTAL HTD SQ FT	GARAGE	_		
Water Supply: X County Ex	isting Well New Well (# of dwellings using well) *Must have operable	e water before final
Sewage Supply: New Septic Tank	(Need to Co	omplete New Well Application at the	e same time as New Ta	<mark>nk</mark>)
	I Health Checklist on other sid	e of application if Septic)	-) () voo (
		·) of tract listed above:	
Does the property contain any easement	· ·	<u></u>		or Oakada
Structures (existing or proposed): Single	family dwellings:	Manufactured Homes:	Other (spe	cify): 2 sneas
If permits are granted I agree to conform I hereby state that foregoing statements				
John	C Roberts		2/2021	·
Signatu	ure of Owner or Owner's Age	ent	Date	orty including but not limited
it is the owner/applicants responsi	bility to provide the coulity w	The arry applicable information at	our the subject brobe	orty, including but not inflited

to: boundary information, house location, underground or overhead easements, etc. The county or its employees are not responsible for any incorrect or missing information that is contained within these applications.***

*This application expires 6 months from the initial date if permits have not been issued**

APPLICATION CONTINUES ON BACK

strong roots · new growth



This application expires 6 months from the initial date if permits have not been issued

This application to be filled out when applying for a septic system inspection.

County Health Department Application for Improvement Permit and/or Authorization to Construct

IF THE INFORMATION IN THIS APPLICATION IS FALSIFIED, CHANGED, OR THE SITE IS ALTERED, THEN THE IMPROVEMENT PERMIT

OR AUTHORIZATION TO CONSTRUCT SHALL BECOME INVALID. The permit is valid for either 60 months or without expiration depending upon documentation submitted. (Complete site plan = 60 months; Complete plat = without expiration)

□ Environmental Health New Septic System

- <u>All property irons must be made visible</u>. Place "pink property flags" on each corner iron of lot. All property lines must be clearly flagged approximately every 50 feet between corners.
- Place "orange house corner flags" at each corner of the proposed structure. Also flag driveways, garages, decks, out buildings, swimming pools, etc. Place flags per site plan developed at/for Central Permitting.
- Place orange Environmental Health card in location that is easily viewed from road to assist in locating property.
- If property is thickly wooded, Environmental Health requires that you clean out the <u>undergrowth</u> to allow the soil evaluation to be performed. Inspectors should be able to walk freely around site. **Do not grade property**.
- All lots to be addressed within 10 business days after confirmation. \$25.00 return trip fee may be incurred for failure to uncover outlet lid, mark house corners and property lines, etc. once lot confirmed ready.

□ Environmental Health Existing Tank Inspections

- Follow above instructions for placing flags and card on property.
- Prepare for inspection by removing soil over **outlet end** of tank as diagram indicates, and lift lid straight up (*if possible*) and then **put lid back in place**. (Unless inspection is for a septic tank in a mobile home park)
- DO NOT LEAVE LIDS OFF OF SEPTIC TANK

"MORE INFORMATION MAY BE REQUIRED TO COMPLETE ANY INSPECTION"

<u>SEPTIC</u>		
If applying	for authorization	on to construct please indicate desired system type(s): can be ranked in order of preference, must choose one.
{}} Acce	pted	$\{_\}$ Innovative $\{_\}$ Conventional $\{_\}$ Any
{}} Alter	rnative	{}} Other
	•	the local health department upon submittal of this application if any of the following apply to the property in "yes", applicant MUST ATTACH SUPPORTING DOCUMENTATION :
{}}YES	{ <u>x</u> } №	Does the site contain any Jurisdictional Wetlands?
{}}YES	$\{\underline{x}\}$ NO	Do you plan to have an <u>irrigation system</u> now or in the future?
{}}YES	{ <u>x</u> } NO	Does or will the building contain any drains? Please explain
{ <u>x</u> }YES	{}} NO	Are there any existing wells, springs, waterlines or Wastewater Systems on this property?
{}}YES	{ <u>x</u> } №	Is any wastewater going to be generated on the site other than domestic sewage?
{}}YES	{ <u>x</u> } №	Is the site subject to approval by any other Public Agency?
{ <u>x</u> }YES	{}} NO	Are there any Easements or Right of Ways on this property?
{ <u>x</u> }YES	{}} NO	Does the site contain any existing water, cable, phone or underground electric lines?
		If yes please call No Cuts at 800-632-4949 to locate the lines. This is a free service

I Have Read This Application And Certify That The Information Provided Herein Is True, Complete And Correct. Authorized County And State Officials Are Granted Right Of Entry To Conduct Necessary Inspections To Determine Compliance With Applicable Laws And Rules. I Understand That I Am Solely Responsible For The Proper Identification And Labeling Of All Property Lines And Corners And Making The Site Accessible So That A Complete Site Evaluation Can Be Performed.

Residential Subsurface Wastewater Treatment and Disposal System Proposal

Property:
7411 NC 210 N
Angier, NC
PIN: 0673-14-0317.000
Harnett County, NC
Ground Truth Job # 21-147

Prepared For:

Professional Property Services, Inc. 18335 Old Statesville Road, Unit A Cornelius, NC 28031

Prepared By:



Ground Truth Soil Consulting, PLLC 1302 Roberts Road Newport, NC 28570

(252) 725-1320

August 2, 2021

John C. Roberts

INTRODUCTION & SITE DESCRIPTION

A Soil & Site Evaluation was performed for NCDOT Parcel 111 located at 7411 N C 210 N, Angier, NC (PIN: 0673-14-0317.000). Ground Truth Soil Consulting, PLLC (Ground Truth) was retained to prepare a proposal for an on-site wastewater treatment and disposal system that would allow for relocation of a portion of the existing septic system of a 3-bedroom home (360 GPD). The lot was evaluated in accordance with North Carolina statutes for waste disposal ("Laws and Rules for Sewage Treatment and Disposal Systems", amended December 6, 2018").

The NCDOT project R5705A is proposed to potentially impact the existing septic drainfield. A relocation permit is requested to relocate a portion of septic drainfield.

The field survey was conducted in June and July 2021 by John C. Roberts, LSS. Soil borings were advanced via a hand auger and evaluated under moist conditions using procedures listed in the *Field book for Describing and Sampling Soils, Version 3.0.* Soil color was determined using a Munsell Soil Color Chart. Observations of the landscape as well as soil properties (depth, texture, structure, soil wetness, restrictive horizons, etc.) were recorded. It was determined sufficient amount of Provisionally Suitable Group II and III soils are available within the project area relocate the last 30-ft of the existing septic drainline upslope 9-ft from its current location. The relocation of the septic drainline is to prevent potential impacts from the proposed NCDOT permanent utility easement (PUE). Sufficient area of Provisionally Suitable soils also exists to support a pump to conventional repair system.

LOCATION

The lot is located at 7411 N C 210 N, Angier, NC.

PLANS AND SPECIFICATIONS

A. Septic Tank

- 1. The septic tank shall replaced if needed. The septic tank will be State approved (Section .1953 of 15A NCAC 18A), watertight, structurally sound, and 1,000 gallons in capacity (at minimum).
- 2. The septic tank shall be fitted with an approved effluent filter.
- 3. It is the responsibility of the septic contractor to thoroughly inspect the septic tank prior to accepting delivery to assure that the tanks have had time to properly cure and are free of cracks or other structural deficiencies.

B. Pipes and Fittings

- 1. All discharge piping, connectors and supply lines should be made of SCH 40 PVC.
- 2. All joints must be properly "welded" utilizing the appropriate PVC cement for each application.

C. Distribution Method

1. It existing septic drainline is fed via gravity flow. The relocated septic drainline will need to be installed deep enough for continued gravity flow.

D. Drainfield Installation-Initial

- 1. The relocated drainline location has been laid out on-site utilizing metal stemmed flags. Only the last 30-ft of the septic drainline is proposed to be relocated 9-ft upslope. The property owner/builder should mark this area and isolate it as much as possible from construction traffic.
- 2. Under no circumstances shall any construction take place within the drainfield area while the soil is in a wet condition.
- 3. The specified system is a gravity-flow system. Conventional gravel drainlines, or equivalent will be utilized. Drainlines shall be installed so that gravity flow can be utilized.
- 4. The drainfield consists of one (1) lateral trench. The relocated portion shall be constructed at the same gravel width and gravel depth as the existing drainline.
- 5. The laterals are to be installed keeping the individual trench bottoms level from beginning to end.
- 6. The trenches should be left open for the final inspection by the HCEH.

E. Final Landscaping

- 1. Final cover over the drainfield shall be at least 6 inches deep. If additional cover is needed, Group II (sandy loam) or Group III (sandy clay loam) soil shall be utilized.
- 2. The drainfield shall be shaped to shed rainwater and be free from low spots.
- 3. The drainfield area should be planted with grass as soon as possible to prevent erosion. The soil should be limed (if necessary) and fertilized prior to planting. After applying grass seed, the area should be heavily mulched with straw or other suitable material.

F. Utility Conflicts

- 1. The builder and property owner must take special care in planning for water, power, gas, telephone and cable lines. These utilities shall be kept clear of all parts of the septic system and its proposed repair area. Improper planning for underground utilities can negatively impact the installation and, in some cases, cause irreparable damage and permit revocation. If there are any questions regarding preferred routes, contact the HCEH as soon as possible.
- 2. Lawn irrigation should not be placed over the drainfield area.

MAINTENANCE

G. In General

- 1. The owner must maintain the drainfield area through periodic mowing. The drainfield must not be allowed to become overgrown.
- 2. The septic tank should be pumped every 4 years or when the solids within the septic tank reach an elevation that is equivalent to 25 percent of the volume of the tank. In some situations, the tanks may need to be pumped more frequently. If using a garbage disposal, it is recommended that the homeowner has the septic and pump tanks cleaned out annually.
- 3. When it becomes necessary to clean the effluent filter, the filter should be removed and the accumulated debris washed back into the septic tank not onto the lawn.
- 4. Any damp areas, leakages or malfunctions in the drainfield area should be addressed immediately.
- 5. Divert gutter downspouts and surface water runoff away from the septic tanks and septic drainfield.

DESIGN SPECIFICS

Initial System

Daily Design Flow: 360 GPD – 3-bedroom house Septic Tank Size: 1,000 Gallons (minimum)

Effluent Loading Rate: 0.5 GPD per sq. ft. Drainfield Type: Gravel or Equivalent

Distribution Method: N/A
Number of Drainlines: One

Total Trench Length to Installed: 30 Linear Feet at the End

Maximum Trench Depth: As needed Final Cover Requirement: 6 Inches

Repair Specifics

Effluent Loading Rate: 0.4 GPD per sq. ft.

Drainfield Type: Accepted Systems Quick 4 Chambers or Equivalent

Distribution Method: Pump to Serial

Total Trench Length: (3) 3 Wide x 75' Long

Maximum Trench Depth: 20 Inches Final Cover Requirement: 6 Inches





Ground Truth Soil Consulting, PLLC

7411 NC 210 N Angier, NC PIN: 0673-14-0317.000

Soil and Site Evaluation

Harnett County

Scale:

50 100 ft


Figure

Date: June 2021

1

GT Job No. 21-148







Ground Truth Soil Consulting, PLLC

7411 NC 210 N Angier, NC PIN: 0673-14-0317.000

Soil and Site Evaluation

Harnett County

Scale:

0 30 60 ft


Figure

Date: June 2021

2

GT Job No. 21-148







Ground Truth Soil Consulting, PLLC

7411 NC 210 N Angier, NC PIN: 0673-14-0317.000

Soil and Site Evaluation

Harnett County

Scale:

Not to Scale

Figure

Date: July 2021

3

GT Job No. 21-148

