

August 24th, 2021

John Roberts
1302 Roberts Rd
Newport, NC 28570

Re: Status of Permit Application-EH2108-0001

Mr. Roberts,

An attempt was made to evaluate your property for issuing a Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are Set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. Use orange flags to mark house box.
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs cleared
- 5. Driveway not shown on site plan (Revision Required)
- 6. Backhoe pits required

7. Other- Unable to approve proposal. Additional information required. Soil profile and proposal shall be provided for proposed trench addition to be deeper than 36in. Existing tank shall be located. If under driveway tank replacement shall be included or if tank does not meet current safety standards. No drain line shall cross an area subject to traffic (driveway). All plumbing shall be tied into the tank. No greywater lines.

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy: Central Permitting