

August 31st, 2021

Re: Status of Repair Application: EH2108-0020

Mrs. Garner

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (As soon as this is done I can release the permit)
- 2. Use orange flags to mark house box.
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs cleared
- 5. Driveway not shown on site plan (Revision Required)
- 6. **Backhoe pits required**
- 7. Other-

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

MO/KH

Copy: Central Permitting