

October 8, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Tracy Clark
225 Green Street Suite 910
Fayetteville, NC 28301

ph: 910-893-7547
fax: 910-893-9371

RE: Relocation Application # EH2109-0016

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Unable to approve – Proposed septic system encroaches on existing property line. Entire proposed septic area is across property line. Revise paperwork to include entire system on existing parcel or combine lot with adjacent parcel.

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting