

November 4th, 2021

Patrick Patterson
41 Sidwell Ct
Fuquay Varina, NC 27526

Re: Status of Repair Application

Mr. Patterson

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (\$25.00 Fee incurred)

2. Use orange flags to mark house box.

3. Directions not clear to property (\$25.00 fee incurred)

4. Property needs cleared

5. Driveway not shown on site plan (Revision Required)

6. Backhoe pits required

7. **Other- Tank affluent above outlet tee. D-Box full. No drainfield surfacing. Repair would require above ground pool removal, property irons and lines marked, pump system added, and potential tree removal.**

Septic maintenance advised. No permit required. Drainfield blockage appears likely. Pump down tank, pump out d-box, replace d-box (if required), camera/snake drain lines, and clear blockages or crushes. Advised extensive maintenance in advance of apparent expensive / unorthodox repair options.

Your application will be put on hold until the selected items above have been addressed.
Any questions I can be reached at 910-893-7547 between 8:00am -9:00am Monday-Friday.

Sincerely,



Andrew Currin R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy: Central Permitting