

North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology Certificate of Analysis

4312 District Drive MSC 1918 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com Phone: 919-733-7308 Fax: 919-715-8611

FINAL REPORT

Report to: ANDREW CURRIN

HARNETT CO ENVIRONMENTAL HEALTH

307 CORNELIUS HARNETT BLVD

Lillington, NC 27546

Name of System:

David Gardner

235 Gardner Camp Road

Angier, NC 27501

EIN: 566000306EH	Delivery: NC Courier		Harnett County
StarLiMS ID: ES211202-0006	Date Collected: 12/01/2021 Date Received: 12/02/2021	 6:00 By: 7:35 By:	Andrew Currin Krystal Plemmons
Sample Source: Well water Sample Type: Treatment:	Sampling Point: outdoor spigot GPS No. Well Permit No.		

Comment:

Colilert Profile Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			12/02/2021
E. coli	Absent			12/02/2021

Report Date: 12/03/2021 Reported By: KPLEMMONS

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.