



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** ANDREW CURRIN

**Name of System:**

**HARNETT CO ENVIRONMENTAL HEALTH**  
 307 CORNELIUS HARNETT BLVD  
 Lillington, NC 27546

**James Lee Gwen**  
 34 Camilla Road  
 Angier, NC 27501

**EIN:** 566000306EH

**Delivery:** NC Courier

**Harnett County**

StarLIMS ID: **ES220223-0041**

Date Collected: 02/22/2022

Time Collected: 10:30

By: Andrew Currin

Date Received: 02/23/2022

Time Received: 07:39

By: Angela Heybroek

Sample Source: Well water

Sampling Point: rear spigot

Sample Type:

GPS No.

Treatment:

Well Permit No.

Comment:

**Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			02/23/2022
E. coli	Absent			02/23/2022

**Report Date:** 02/24/2022

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: ANDREW CURRIN**

**Name of System:**

**HARNETT CO ENVIRONMENTAL HEALTH**  
 307 CORNELIUS HARNETT BLVD  
 Lillington, NC 27546

**James Lee Owen**  
 34 Camillia Rd  
 Angier, NC 27501

**EIN: 566000306EH**

**Delivery: NC Courier**

**Harnett County**

StarLiMS ID: **ES220202-0060**

Date Collected: 02/01/2022

Time Collected: 11:30

By: Andrew Currin

Date Received: 02/02/2022

Time Received: 08:01

By: Krystal Plemmons

Sample Source: Well water

Sampling Point: Rear spigot

Sample Type:

GPS No.

Treatment:

Well Permit No.

Comment:

**Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			02/02/2022
E. coli	Absent			02/02/2022

**Report Date:** 02/03/2022

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.