

February 24th, 2022

Julio Cesar Perez Velazquez
521 Clayton Rd
Angier, NC 27501

RE: Permit Application for: 50 Brim Lane, Angier

Dear Mr. Velazquez,

An attempt was made to evaluate your property for the purpose of issuing a Permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal and D-Box (\$25.00 fee incurred).

2. Have system pumped out

3. Replace sanitary T

4. Other – House box needs to be marked off.

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7525 ext 1 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James Manhart III, R.E.H.S.
Environmental Health Program Specialist
Harnett County Department of Public Health

JM/kh

Copy - Central Permitting