

EN 2262-0020

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: HCP  
 Address: 1142 N 55E  
 Proposed Facility: S/S  
 Location of Site: S/S  
 Water Supply:  Public  Individual  Well  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process

Applicant: 600 WIND LANE + DUP.  
 Date Evaluated: 03/09/2022  
 Design Flow (.1949): 1800 GPD  
 Property Recorded:  
 Property Size:  
 Spring  Other

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1.7	L 3-4%	0-14	GL LS	VL NSNP					PS
		14-38	SL CLAY LOAM	FL SP	7.5-27.1 @ 36"	38			0.375
2.4, 1.8	L 3-4%	0-14	GL LS	VL NSNP					0/PS
		14-34	SL CLAY LOAM	FL SP	7.5-27.1 @ 32"	34			0.375
3.5	L 3-4%	0-12	GL LS	VL NSNP					0/PS
		12-32	SL CLAY LOAM	FL SP	7.5-27.1 @ 30"	32			0.375

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>UNDESIRABLE / PROVISIONALLY SUITABLE</u> Evaluated By: <u>ANDREW CORBIN, TETS</u> Others Present:
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<u>25% TSD</u>	<u>25% TSD</u>	
Site LTAR	<u>0.375</u>	<u>0.375</u>	


COMMENTS: \_\_\_\_\_

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM		SP-SLIGHTLY STICKY	
CC-CONCLAVE SLOPE		CL-CLAY LOAM		P-PLASTIC	
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM		VP-VERY PLASTIC	
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE  
 SG-SINGLE GRAIN  
 M- MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)



P.L.