

March 23, 2022

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Mr. Jesse Ryals  
763 Butts Road  
Angier, NC 27501

ph: 910-893-7547  
fax: 910-893-9371

**Re: Status of Repair Permit for: 763 Butts Road Angier NC 27501**

Mr. Jesse Ryals:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- \_\_\_\_\_ 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- \_\_\_\_\_ 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- \_\_\_\_\_ 3. Directions not clear to property (*\$25.00 fee incurred*)
- \_\_\_\_\_ 4. Property needs only brush or vegetation removed
- \_\_\_\_\_ 5. Driveway not shown on site plan
- \_\_\_\_\_ 6. Backhoe pits required
- X** **7. Other- System exhibits surfacing at end bottom line. Owner informed a repair permit can be issued for new lines if required. Advised to perform extensive system maintenance to rule out any simple repair options. Advised to pump tank, evaluate d-box, snake/camera lines, and evaluate for any blockages (sludge, roots, etc.). If maintenance does not alleviate issue reconfirm for line replacement permit.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

AC/slc  
Copy: Central Permitting  
Enclosures