

March 23, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Mr. Anthony Chavis
24 Fairview Village Road
Dunn, NC 28334

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 24 Fairview Village Road Dunn, NC 28334

Mr. Chavis:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Soil evaluation revealed extremely shallow soils. Secondary review and/or soil scientist proposal may be required prior to any new drain field permitted. Advised to perform extensive and detailed system maintenance (Tank review, distribution method, blockages, etc.) prior to proceeding to unorthodox system requirement.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting
Enclosures