

April 18, 2022

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Margaret Windley-Garcia  
240 Kings Way  
Angier, NC 27501

ph: 910-893-7547  
fax: 910-893-9371

**Re: Status of Repair Permit for: 240 Kings Way Angier, NC 27501**

Mrs. Windley-Garcia:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- \_\_\_\_\_ 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- \_\_\_\_\_ 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- \_\_\_\_\_ 3. Directions not clear to property (*\$25.00 fee incurred*)
- \_\_\_\_\_ 4. Property needs only brush or vegetation removed
- \_\_\_\_\_ 5. Driveway not shown on site plan
- \_\_\_\_\_ 6. Backhoe pits required
- 7. Other- Septic Maintenance Advised – Advised to have licensed septic contractor uncover D-box, determine condition of existing drain field, and determine why only middle line is accepting affluent. Middle line is surfacing while top and bottom lines are dry. Extensive system maintenance is advised. Operational Permit calls for pump to repair in front yard. May require utility relocation. Repair may not be financially optimal to homeowner. Coordinate with Environmental Health with any questions, comments, or concerns.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

AC/slc