Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 1184 Jim Christian Rd (SR 1302) ISSUED TO: Greg Garretson SUBDIVISION REPAIR X EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Existing Home Proposed Wastewater System Type: pump to 25% reduction Projected Daily Flow: 240 Number of bedrooms: 2 Number of Occupants: 4 Basement Yes May be required based on final location and elevations of facilities ☐ No Pump Required: XYes Type of Water Supply: Community Public Well Distance from well ______feet Five years Permit valid for: No expiration Permit conditions: Date: 08-31-22 SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Greg Garretson PROPERTY LOCATION: 1184 Jim Christian Rd (SR 1302) NOISIVIDAUS Facility Type: Existing Home Expansion X Repair Basement? Yes No Basement Fixtures? Yes Type of Wastewater System** (Initial) Wastewater Flow: GPD (See note below, if applicable) pump to 25% reduction Number of trenches 1 Installation Requirements/Conditions Exact length of each trench 200 Septic Tank Size existing gallons Trench Spacing: 9 Pump Tank Size 1000 Trenches shall be installed on contour at a Soil Cover: 6 gallons Maximum Trench Depth of: 22 (Maximum soil cover shall not exceed inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: _____ ft. TDH vs. __ inches below pipe inches above pipe Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Maj Construction Authorization Expiration Date: 10-30-22

Harnett County Department of Public Health Site Sketch

Property Location: 1184 Jim Christian Rd (SR 1302)	
Issued To: Greg Garretson Subdivision	Lot #
Authorized State Agent: Mol WREHS	Date: <u>08-31-22</u>
- Add a pump Tank of 1000 galle - Add 5 (40'x3') Trenches on hills in (Line, Ara Worked with blue + whi	de at back of property
A Call before Install with guesti	ons
40.2.10	
Jan 40:! [Shuy]	
Jeg (1) Stor	
E Was	
146n2g	
This drawing is for illustrative purposes only. System installation must meet	all pertinent laws, rules, and regulations
Pond	