## Harnett County Department of Public Health

## Improvement Permit A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 3335 Shady Grove Rd (SR 2050) ISSUED TO: Deborah Carter SUBDIVISION NEW | EXPANSION Site Improvements required prior to Construction Authorization Issuance: REPAIR X Type of Structure: existing Proposed Wastewater System Type: GTR Projected Daily Flow: 360 GPD Number of Occupants: 6 Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities Pump Required: Yes X No Type of Water Supply: Community Public Well Distance from well \_\_\_\_\_\_feet X Five years Permit valid for: No expiration Permit conditions: Date: 4-29-22 Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 3335 Shady Grove Rd (SR 2050) ISSUED TO: Deborah Carter SUBDIVISION X Repair Facility Type: existing Expansion Basement Fixtures? Yes Basement? Yes X No (Initial) Wastewater Flow: 360 Type of Wastewater System\*\* GPD (See note below, if applicable ) Tank Only (Repair) Installation Requirements/Conditions Number of trenches Trench Spacing: \_\_\_\_\_ Feet on Center Exact length of each trench Septic Tank Size 1000 gallons Soil Cover: Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Maximum Trench Depth of: (Maximum soil cover shall not exceed \_inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_\_ft. TDH vs. \_\_\_ inches below pipe Aggregate Depth: inches above pipe inches total Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Meh de RGH-5 Date: 4-29-22 Construction Authorization Expiration Date: 06-29-22

## Harnett County Department of Public Health Site Sketch

Property Location: 3335 S Issued To: Deborah Carter	lady Glove Ru (	Subdivision _		Lot	#
Authorized State Agent: _	Mah an REHS			Date: 4-29-22	
Ank 5' form How II and Fill in at Tank a Connect o Tank TO Ting Drain		Wooded	The same live	KISTING Brown	

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.