

May 2, 2022

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Kristin Wells  
254 Mistywood Drive  
Fuquay-Varina, NC 27526

ph: 910-893-7547  
fax: 910-893-9371

**Re: Status of Repair Permit for: 254 Mistywood Drive Fuquay-Varina, NC 27526**

Ms. Wells:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- \_\_\_\_\_ 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- \_\_\_\_\_ 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- \_\_\_\_\_ 3. Directions not clear to property (*\$25.00 fee incurred*)
- \_\_\_\_\_ 4. Property needs only brush or vegetation removed
- \_\_\_\_\_ 5. Driveway not shown on site plan
- \_\_\_\_\_ 6. Backhoe pits required

**X 7. Other- System appears to be functioning normal at time of inspection with tank operating at normal levels and no surfacing in yard. Unapproved above ground pool appears to be placed on existing septic system. Homeowner states toilets gurgle and slow drain during heavy rains. Homeowner advised to coordinate with licensed septic contractor to do routine maintenance (pumping, reviewing, probing, snaking, camera line, etc.) and inspection of existing system. Homeowner advised pump system likely required on any needed repair. Additionally, surveyed property corner irons and property lines shall be marked if any permitted drain lines required.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

AC/slc