

May 9, 2022

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

A&N Properties Group LLC  
3843 NC 55 E  
Dunn, NC 28334

ph: 910-893-7547  
fax: 910-893-9371

**Re: Status of Repair Permit for: 3843 NC 55 E Dunn, NC 28334**

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- \_\_\_\_\_ 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- \_\_\_\_\_ 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- \_\_\_\_\_ 3. Directions not clear to property (*\$25.00 fee incurred*)
- \_\_\_\_\_ 4. Property needs only brush or vegetation removed
- \_\_\_\_\_ 5. Driveway not shown on site plan
- \_\_\_\_\_ 6. Backhoe pits required
- X 7. **Other- No suitable soil found in property. No permitted (new lines) repair available. Owner advised to follow the following procedures.**

- 1) **Coordinate with a licensed septic contractor to perform system maintenance of existing system. System appears to be inhibited by root intrusion. System flow may be reobtained by removing overgrowth, snaking or camera drain field, fixing crushed/clogged, etc.**
- 2) **Coordinate with Public Utilities for possible access to sewer. Gravity line appears at front of property.**
- 3) **Place home on pump and haul for routine pumping**
- 4) **Coordinate with licensed soil scientist or soil engineer on alternative septic options**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

AC/slc