

May 9, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Melodee Carlton
9966 US 421 S
Erwin NC 28339

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 9966 US 421 S Erwin NC 28339

Ms. Carlton:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- _____ 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- _____ 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- _____ 3. Directions not clear to property (*\$25.00 fee incurred*)
- _____ 4. Property needs only brush or vegetation removed
- _____ 5. Driveway not shown on site plan
- _____ 6. Backhoe pits required

X 7. Other- System maintenance advised. Property appears to have sufficient space for repair if required. Applicant advised to consult with licensed septic contractor to perform system maintenance on existing system. Contractor advised to snake/camera lines for blockages, unclog accordingly, and replace d-box. Contractor advised to use all means of maintenance to repair. Permit required for lines/tank replacement. Coordinate with Environmental Health with any questions, comments, or concerns.

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting
Enclosures