

CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Derek + Deborah Horne New Installation Septic Tank
 Property Location: SR# HWY 27 Repairs Nitrification Line
 Subdivision — Lot # —
 TAX ID# — Quadrant # —
 Contractor: Kenneth Woakes Registration # —


Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50'+ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other —
 Size of tank: Septic Tank: 1000 gallons Pump Tank: — gallons
 Subsurface Drainage Field: No. of ditches 2 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 14-20" in.
 French Drain: — Linear feet

PERMIT NO. 09974

Date: NEW 11-13-95
 Inspected by: James Markant
 Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Derek + Deborah Hawkins New Installation Septic Tank
Property Location: SR# HWY 27 Repairs Nitrification Line

Subdivision _____ Lot # _____

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 2 Lot Size: 2.75 ACRES

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-20 in.


French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: NEW 11-22-95
Signed: James M. ...

Environmental Health Specialist

VOID AFTER 5 YEARS



SITE/SOIL EVALUATION FOR ON-SITE WASTE WATER

APPLICANT: Derek + Delmat Hopkins PHONE: _____ APPLICATION DATE: _____
 ADDRESS: _____
 COUNTY: HARNETT PROPERTY SIZE: _____ PROPOSED FACILITY: _____
 LOCATION OF SITE: _____
 WATER SUPPLY: On-Site Well _____ Community _____ Public Other _____ EVALUATION BY: Auger Boring Pit _____ Cut _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L	L	L	L				
SLOPE (%)	.1940	6-5	6-5	0-5	0-8	0-5	0-5				
HORIZON 1 DEPTH		0-30	0-30	0-30	0-24	0-24	0-24				
Texture Group	.1941(A)(1)	SL	SL	SL	SC	SC	SC				
Consistence	.1941	FR	FR	FR	FR	FR	FR				
Structure	.1941(A)(2)	GR	GR	GR	AR	AR	AR				
Mineralogy	.1941(A)(3)	1:1	1:1	1:1	2:1	2:1	2:1				
HORIZON 2 DEPTH		30-70	30-30	30-30							
Texture Group	.1941(A)(1)	SL	SL	SL							
Consistence	.1941	FR	FR	FR							
Structure	.1941(A)(2)	AR	AR	AR							
Mineralogy	.1941(A)(3)	2:1	2:1	2:1							
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942										
RESTRICTIVE HORIZON	.1944										
PROLITE	.1943/1956										
CLASSIFICATION	.1948										
LONG TERM ACCEPTANCE RATE	.1955	.4	.4	.4	U	U	U				

AVAILABLE SPACE (.1945): _____ SITE LONG TERM ACCEPTANCE RATE: _____
 OTHER FACTORS (.1946): _____ SYSTEM TYPE: _____
 SOIL CLASSIFICATION (.1948): _____

EVALUATED BY: JHW & TJS OTHERS PRESENT: _____

COMMENTS:

