

# CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Currin Builders Inc  New Installation  Septic Tank  
Property Location: SR# 1446  Repairs  Nitrification Line  
Subdivision Westford Lot # 7  
Contractor: Currin Builders Inc Registration # 34  
Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 50+ ft.

Following are the specifications for the sewage disposal system on above captioned property.


Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-24 in.  
French Drain: \_\_\_\_\_ Linear feet

PERMIT NO. 8455

Date: 11-24-93

Inspected by: Thomas J. Boyce

Environmental Health Specialist



# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Curvin Builders Inc.  New Installation  Septic Tank  
 Property Location: SR# 1446  Repairs  Nitrification Line  
Parfoz Rd.  
 Subdivision Westford Lot # 7  
 Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Number of Bedrooms Proposed: 3 Lot Size: .671  
 Basement with Plumbing:  Garage:   
 Water Supply:  Well  Public  Community  
 Distance From Well: 50 ft. +

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface No. of exact length width of depth of  
 Drainage Field ditches 3 of each ditch 100 ft. ditches 3 ft. ditches 18-2 in.  
 French Drain required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 09-09-93  
 Signed: J.L.H. Byrd Jr.  
 Environmental Health Specialist

VOID AFTER 5 YEARS

