

July 12, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

John Walsh
1329 Route 390
Greentown, PA 18426

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 266 Young Road

Mr. Walsh:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Tank was completely covered. Tank and tank lids shall be made accessible for inspection and septic approval. Unable to verify repair needs without tank exposure. Per provided report, it is recommended that a licensed septic contractor review the flow to the existing drain field. Existing report only reviewed existing tank and distribution box. Drain field function is advised to review for adequate flow prior to tank replacement.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting
Enclosures