

July 22, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Thomas Anthony Lee
1820 Hodges Chapel Road
Benson, NC 27504

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 1820 Hodges Chapel Road

Mr. Lee:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Septic Maintenance Advised – Only inlet end of tank exposed and recently pumped. Per owner, only inlet end of tank ever pumped. Effluent has been backing up into home but no surfacing noted in yard. Owner advised to coordinate with a license septic contractor to review system for maintenance remedies. Potential drain line blockage, root intrusion, etc. possible. Soils exhibit no groundwater intrusion (Dry). Should general maintenance be unsuccessful, owner shall locate surveyed property irons and reconfirm for permitting.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc