Harnett County Department of Public Health

Improvement Permit A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: GII VANN LANZ (MELDOSLAVE AD .- 5/21715) ISSUED TO: CLANEDCE E. BNAGFOUT SUBDIVISION REPAIR X EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: EXT 3-BEDROOM STAD 25/0 TENETION STD. Proposed Wastewater System Type: _ GPD Projected Daily Flow: 3 Number of Occupants: 6 Number of bedrooms: Basement Yes No May be required based on final location and elevations of facilities Pump Required: Yes ₩ No Type of Water Supply: Community Public Well Distance from well Five years Permit valid for: No expiration Permit conditions: 09/20/2022 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules . 1950, . 1952, . 1954, . 1955, . 1956, . 1957, . 1958. and . 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: GI VAND LANE (NEADOWARD 105) ISSUED TO: CLANENCE IE. BANEFOOT Expansion Facility Type: EXT 3-32 STD Basement? Yes No Basement Fixtures? Yes (Initial) Wastewater Flow: 360 GPD Type of Wastewater System** NOT APPLICABLE (See note below, if applicable) 25% rEDUCTION STOTEM (Repair) Number of trenches Installation Requirements/Conditions Trench Spacing: _______ Feet on Center Exact length of each trench 120 Septic Tank Size 1000 gallons Pump Tank Size _____ Trenches shall be installed on contour at a gallons Maximum Trench Depth of: 24 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) _ inches below pipe Pump Requirements: _____ ft. TDH vs. __ nches above pipe WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Date: 69/20/2022

Construction Authorization Expiration Date: 07/26/2627

Authorized State Agent: All Com , nor

ANDREW CURIN

Harnett County Department of Public Health Site Sketch

Property Location: 611 VAND LANZ	(MELTOGOLANG 1D52 1715)		
Issued To: CLANDEZ E. OMEFOOT	Subdivision		Lot #
Authorized State Agent:	TWO CONGEN	Date:	09/20/2022

* NEUTEN PLUMBING PLE-INSTACL

LO PUMP MAY BE RECUITED IF TO DIEFP

X 5007 MIN POND SETBACK EVERT TIGHT]

