

September 22, 2022

www.harnett.org

Jesus Luna
27 Stone Lane
Dunn, NC 28334

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Repair Permit for: 40 Clesters Way Dunn, NC 28334

Mr. Luna:

An attempt was made to evaluate your property for the purpose of issuing a Repair Permit. The evaluation could not be completed for one or more of the following reasons.

- _____ 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible.
- _____ 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- _____ 3. Directions not clear to property *(\$25.00 fee incurred)*
- _____ 4. Property needs only brush or vegetation removed
- _____ 5. Driveway not shown on site plan
- _____ 6. Backhoe pits required
- X 7. Other- No Permit Issued - Septic fluid surfacing on back of property toward wood line. Small hole dug out on tank but not fully uncovered. Unconventional black pipe on top of tank. Licensed septic contractor shall fully uncover and evaluate tank and septic system for functionality and condition. Septic contractor shall coordinate with Harnett County Environmental Health to determine procedure to move forward.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/slc