

114158-114029  
101558-101118

# Harnett County Department of Public Health

PERMIT # EH 2205-0012

## Operation Permit

New Installation  Septic Tank  Nitrification Line  Repair  Expansion

PROPERTY LOCATION: 521429 Chalkhooter RD

Name: (owner) Henry Alanco SUBDIVISION Avery Pond LOT # 160

System Installer: Quincy Septic


Basement with plumbing:  Garage  Number of Bedrooms 3

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet

System Type: CONTAIN DRAINAGE INSTALLED Types V and VI Systems expire in 5 years.

(In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



### PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: \_\_\_\_\_  
Subsurface system operator required? Yes  No   
If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: \_\_\_\_\_
- V. Other: \_\_\_\_\_

D-Box  Pump  Alarm  H2O Line  PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system:  Conventional  Other CONTAIN DRAINAGE Septic Tank: Checked FOR LEAKS gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field: No. of ditches 17 exact length of each ditch 65 feet width of ditches 65 feet depth of ditches 65 inches

French Drain Required: \_\_\_\_\_ Linear feet

Authorized State Agent James E. Manhart JR 76HS Date 12-20-24