

## Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Eric Davis      PROPERTY LOCATION: 78 Sydney Dr (NC 27W)  
 SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

NEW       REPAIR       EXPANSION       Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_

Type of Structure: EXISTING HOME

Proposed Wastewater System Type: Tank replacement

Projected Daily Flow: 360 GPD

Number of bedrooms: 3      Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No       May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well      Distance from well \_\_\_\_\_ feet      Permit valid for:  Five years  No expiration

Permit conditions: \_\_\_\_\_

Authorized State Agent: Moh R AHS      Date: 2-16-23      SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

### Construction Authorization (Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Eric Davis      PROPERTY LOCATION: 78 Sydney Dr (NC 27W)  
 SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

Facility Type: Existing Home       New       Expansion       Repair

Basement?  Yes  No      Basement Fixtures?  Yes  No

Type of Wastewater System\*\* \_\_\_\_\_ (Initial) Wastewater Flow: 360 GPD  
 (See note below, if applicable  Task Only (Repair))

<p><b>Installation Requirements/Conditions</b></p> <p>Septic Tank Size <u>1000</u> gallons</p> <p>Pump Tank Size _____ gallons</p>	<p>Number of trenches <u>Existing</u></p> <p>Exact length of each trench _____ feet</p> <p>Trenches shall be installed on contour at a Maximum Trench Depth of: _____ inches                  (Trench bottoms shall be level to +/-1/4" in all directions)</p>	<p>Trench Spacing: _____ Feet on Center</p> <p>Soil Cover: _____ inches                  (Maximum soil cover shall not exceed 36" above the trench bottom)</p>
--	--	--

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM      \_\_\_\_\_ inches below pipe

Aggregate Depth: \_\_\_\_\_ inches above pipe

Conditions: \_\_\_\_\_      \_\_\_\_\_ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.      SEE ATTACHED SITE SKETCH

Authorized State Agent: Moh R AHS      Date: 2-16-23  
 Construction Authorization Expiration Date: 2-16-24


Application # EH 2302-0009

Harnett County Department of Public Health  
Site Sketch

Property Location: 78 Sydney Dr (NC 27W)

Issued To: Eric Davis Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_

Authorized State Agent: Mal RHEHS Date: 2-16-23



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.